

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0305-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HNC11CP007	Range	0 ~ 100
Instrument Description	INDUCED DRAFT FAN B SEAL AIR PRESSURE 1	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501	Cal. Date	17-05-2024
Instrument Location	BOILER 1ST FLOOR		

Environment Condition

Temperature: 29 °C
 Humidity: 51 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
0	4.000	4.001	0.001	0.006	Pass						
25	8.000	8.010	0.010	0.062	Pass						
50	12.000	11.993	-0.007	-0.044	Pass						
75	16.016	16.008	-0.008	-0.050	Pass						
100	20.000	19.998	-0.002	-0.012	Pass						
100	20.000	19.998	-0.002	-0.012	Pass						
75	16.000	16.006	0.006	0.038	Pass						
50	12.000	11.999	-0.001	-0.006	Pass						
25	8.000	8.002	0.002	0.013	Pass						
0	4.016	3.994	-0.022	-0.137	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Hidayat

Calibrated by,



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

