

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1203-24-HI-CAL-10J

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HTA01AA200 Damping Time 0.5 s
Instrument Description U6 IDF OUTLET DAMPER A Inspection Date 24-05-2024
Manufacture CUADRO
Model -
Serial Number R060064
Instrument Location IDF OUTLET B

Environment Condition

Temperature 30.1 °C
Humidity 51 % RH
Traveling Time
Open to Close 05.93 s
Close to Open 09.28 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK
Corrosion Condition OK Not OK
Air Regulator Check OK Not OK
Tightness Check OK Not OK
Accessories Check OK Not OK

Remark

Test Equipment

Description Serial Number Certificate Number Calibration Date
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 25-05-2024

Customer Signature,

Ayron Humardani Putradhi

HERVITAMA
Approved Signatory,

M. Taufiq Nur Fitriyan

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

