

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0724-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HTA10CT002	Range	0 ~ 250
Instrument Description	U6 FGD INLET TEMPERATURE B	Unit	°C
Manufacture	ROSEMOUNT	Out. Signal	4 - 20 mA
Model	644HANAXAR2M4Q4	Max. Deviation	2.5 °C
Serial Number	3637884	Cal. Date	23-05-2024
Instrument Location	BOP	Temp. Element	PT 100

Environment Condition

Temperature 26.3 °C
Humidity 54 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.000	39.800	-0.200	Pass					
62.5	62.500	62.400	-0.100	Pass					
125.0	125.020	124.900	-0.120	Pass					
187.5	187.540	187.330	-0.210	Pass					
250.0	250.010	249.730	-0.280	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 24-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

