

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0725-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HTA10CT003	Range	0 ~ 250
Instrument Description	U6 FGD INLET TEMPERATURE C	Unit	°C
Manufacture	ROSEMOUNT	Out. Signal	4 - 20 mA
Model	644HANAXAR2M4Q4	Max. Deviation	2.5 °C
Serial Number	3637886	Cal. Date	22-05-2024
Instrument Location	BOP	Temp. Element	PT 100

Environment Condition

Temperature 29.1 °C
Humidity 44 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.010	39.780	-0.230	Pass					
62.5	62.500	61.910	-0.590	Pass					
125.0	125.000	124.100	-0.900	Pass					
187.5	187.500	186.600	-0.900	Pass					
250.0	250.000	249.110	-0.890	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 23-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taqid Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

