

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0734-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HTB20CT001	Range	0 ~ 420
Instrument Description	U6 SOOT BLOWER STEAM INLET TEMPERATURE	Unit	°C
Manufacture	ROSEMOUNT	Out. Signal	4 - 20 mA
Model	644HANAXAJ6M4Q4	Max. Deviation	4.2 °C
Serial Number	3639917	Cal. Date	11-05-2024
Instrument Location	GGH	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 25.5 °C  
 Humidity 54 % RH

### Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.900	-0.100	Pass					
105	105.010	105.100	0.090	Pass					
210	210.01	210.200	0.190	Pass					
315	314.980	316.100	1.120	Pass					
420	419.980	421.800	1.820	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
 Date of issue, 12-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person