

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0733-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HTE00CP001 Range 0 ~ 10
Instrument Description U6 ABSORBER MIST ELIMINATOR DIFFERENTIAL PRESSURE Unit mbar
Manufacture ROSEMOUNT Out. Signal 4 - 20 mA
Model - Max. Error 0.5 %
Serial Number 3666995 Cal. Date 31-05-2024
Instrument Location BOILER PGD 2ND FLOOR

Environment Condition

Temperature 27.2 °C
Humidity 50 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	3.952	3.959	0.007	0.044	Pass						
2.5	8.016	8.076	0.060	0.375	Pass						
5.0	12.032	12.038	0.006	0.037	Pass						
7.5	16.048	16.042	-0.006	-0.037	Pass						
10.0	20.016	20.016	0.000	0.000	Pass						
10.0	20.016	20.016	0.000	0.000	Pass						
7.5	16.032	16.030	-0.002	-0.013	Pass						
5.0	11.984	12.007	0.023	0.144	Pass						
2.5	8.064	8.056	-0.008	-0.050	Pass						
0.0	4.016	4.020	0.004	0.025	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 01-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signature,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alifidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

