

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0307-24-HI-CAL-10C

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LAA10CL005 Range NWL-2600 ~ NWL+500
Instrument Description DEARATOR LEVEL 1 Unit mm
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model - Max. Error 0.5 %
Serial Number - Cal. Date 25-05-2024
Instrument Location TURBINE 4TH FLOOR

Environment Condition

Temperature 33 °C
Humidity 43 % RH

Calibration Result

As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-2600	-2600	-2600	4.000	4.010	0.010	0.063	Pass								
-1825	-1825	-1823	8.000	8.020	0.020	0.125	Pass								
-1050	-1050	-1043	12.000	12.040	0.040	0.250	Pass								
-275	-275	-275	16.000	16.000	0.000	0.000	Pass								
500	500	499	20.000	20.000	0.000	0.000	Pass								

Standard Reference


Description True RMS Multimeter Constant Serial Number 160403266 Certificate Number SCL/23/3123/EY Calibration Date 14-11-2023

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Hendri Setiawan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

