

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0378-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAA10CL005
Instrument Description DEARATOR LEVEL 1
Manufacture YOKOGAWA
Model / Serial Number EJX118A / 91V901799737
Instrument Location TURBINE 4TH FLOOR

Range -2600 ~ 500
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 07-06-2026

Environment Condition

Temperature 27 °C Humidity 61 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-2600	-2551	-2553	4.245	-2.000	-0.065	Pass							
-1825	-1874	-1871	7.789	3.000	0.097	Pass							
-1050	-1046	-1044	12.034	2.000	0.065	Pass							
-275	-288	-287	15.962	1.000	0.032	Pass							
500	500	499	19.998	-1.000	-0.032	Pass							

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 12-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

