

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0379-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAA10CL010 Range -2600 ~ 500
Instrument Description DEAERATOR LEVEL 2 Unit mm
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX118A / 91V9018807377 Max. Error 0.5%
Instrument Location TURBINE 4TH FLOOR Cal. Date 07-06-2026

Environment Condition

Temperature 26 °C Humidity 64 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-2600	-2418	-2426	-	-8.000	-0.258	Pass	-2600	-2541	-2542	4.231	-1.000	-0.032	Pass
-1825	-1774	-1788	-	-14.000	-0.452	Pass	-1825	-1889	-1890	7.664	-1.000	-0.032	Pass
-1050	-1149	-1137	-	12.000	0.387	Pass	-1050	-1176	-1180	11.329	-4.000	-0.129	Pass
-275	-139	-114	-	25.000	0.806	Fail	-275	-256	-259	16.084	-3.000	-0.097	Pass
500	500	501	-	1.000	0.032	Pass	500	500	500	19.999	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 12-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Ivan Hassen Ismari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person