

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0309-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60LAA10CL015 Range: NWL-2600 – NWL+500
 Instrument Description: DEAERATOR LEVEL 3 Unit: mm
 Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA
 Model: - Max. Error: 0.5 %
 Serial Number: - Cal. Date: 25-05-2024
 Instrument Location: TURBINE 4TH FLOOR

Environment Condition

Temperature: 33 °C
 Humidity: 43 % RH

Calibration Result

Data Reading (Transmitter)																
As Found								As Left								
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-2600	-2600	-2581	4.000	4.060	0.060	0.375	Pass									
-1825	-1825	-1806	8.000	8.040	0.040	0.250	Pass									
-1050	-1050	-1028	12.000	12.040	0.040	0.250	Pass									
-275	-275	-254	16.000	16.000	0.000	0.000	Pass									
500	500	523	20.000	19.990	-0.010	-0.063	Pass									

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
True RMS Multimeter Constant	160403266	SCL/23/3123/EY	14-11-2023

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory



M. Taufiq Nur Hidayat

Calibrated by,



R. Heri Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person