

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0310-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAA10CP005	Range	-1 ~ 15
Instrument Description	DEAERATOR PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V73387	Cal. Date	22-05-2024
Instrument Location	TURBINE 4TH FLOOR		

Environment Condition

Temperature 32 °C
Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.9	4.100	4.095	-0.005	-0.031	Pass						
3.0	8.000	7.997	-0.003	-0.019	Pass						
7.0	12.000	11.998	-0.002	-0.013	Pass						
11.0	16.000	15.998	-0.002	-0.013	Pass						
15.0	20.000	20.001	0.001	0.006	Pass						
15.0	20.000	20.001	0.001	0.006	Pass						
11.0	16.000	15.997	-0.003	-0.019	Pass						
7.0	12.000	11.998	-0.002	-0.013	Pass						
3.0	8.000	8.007	0.007	0.044	Pass						
0.0	4.100	4.094	-0.006	-0.037	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 23-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
Applied Laboratory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Kandi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

