

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0382-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAB01CF005
Instrument Description TURBINE DRIVEN BOILER FEEDWATER PUMP A INLET WATER FLOW 1
Manufacture YOKOGAWA
Model / Serial Number EJX130A / 90Y616294
Instrument Location TURBINE 1ST FLOOR

Range 0 ~ 1647.4
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 03-06-2026

Environment Condition

Temperature 31 °C Humidity 72 % RH

Calibration Result

As Found						As Left					
Input [mbar]	Std Output [mA]	Output UUT [mA]	Deviation	Error	Result	Input [mbar]	Std Output [mA]	Output UUT [mA]	Deviation	Error	Result
				[%]						[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
411.900	8.000	7.998	-0.002	-0.013	Pass						
823.700	12.000	11.996	-0.004	-0.025	Pass						
1235.600	16.000	15.995	-0.005	-0.031	Pass						
1647.400	20.000	19.993	-0.007	-0.044	Pass						
1295.600	16.000	15.994	-0.006	-0.038	Pass						
823.700	12.000	11.996	-0.004	-0.025	Pass						
411.900	8.000	7.999	-0.001	-0.006	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P08	14070813	MAL 26031235	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 07-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

