

## CERTIFICATE OF CALIBRATION

### DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0312-24-HI-CAL-10C

#### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

#### Instrument Information

KKS No.: 60LAB01CF010 Range: 0 ~ 1647.4  
Instrument Description: TURBINE DRIVEN BOILER FEEDWATER PUMP A INLET Unit: mbar  
WATER FLOW 2  
Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA  
Model: EJX 130A Max. Error: 0.5 %  
Serial Number: 90Y616295 Cal. Date: 07-05-2024  
Instrument Location: TURBINE 1ST FLOOR

#### Environment Condition

Temperature: 28.1 °C  
Humidity: 51 % RH

#### Calibration Result

Data Reading (Transmitter)						As Left					
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.000	0.000	0.000	Pass						
411.8	8.000	8.013	0.013	0.081	Pass						
823.7	11.998	11.994	-0.004	-0.025	Pass						
1235.6	15.999	16.004	0.005	0.031	Pass						
1647.4	19.998	20.009	0.011	0.069	Pass						
1647.4	19.998	20.009	0.011	0.069	Pass						
1235.6	15.998	15.994	-0.004	-0.025	Pass						
823.7	11.999	12.011	0.012	0.075	Pass						
411.8	7.998	8.010	0.012	0.075	Pass						
0.0	4.000	4.009	0.009	0.056	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 700P05	14270508	S. 22 011 744	20-09-2022

#### Calibration Method

001 / Service-HI / 2019  
Standard Operating Procedure of Pressure Transmitter Calibration

This certificate comprise of 1 page  
Date of issue, 08-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

