

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0313-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAB01CP005	Range	0 ~ 2000
Instrument Description	TBFP A BP SUCTION STRAINER DIFFERENTIAL PRESSURE	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V703345	Cal. Date	08-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature 28.1 °C
Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.000	0.000	0.000	Pass						
500	8.000	8.001	0.001	0.006	Pass						
1000	12.000	11.998	-0.002	-0.013	Pass						
1500	16.000	16.000	0.000	0.000	Pass						
2000	20.000	19.999	-0.001	-0.006	Pass						
2000	20.000	19.999	-0.001	-0.006	Pass						
1500	16.000	15.995	-0.005	-0.031	Pass						
1000	12.000	12.003	0.003	0.019	Pass						
500	8.000	7.999	-0.001	-0.006	Pass						
0	4.000	4.003	0.003	0.019	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 700P05	14270508	S. 22 011 744	20-09-2022

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 09-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Faishol Arwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

