

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0315-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LAB02CF010 Range 0 ~ 1647.4
Instrument Description TURBINE DRIVEN BOILER FEEDWATER PUMP B INLET Unit mbar
WATER FLOW 2
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model EJX130A Max. Error 0.5 %
Serial Number 90Y616297 Cal. Date 07-05-2024
Instrument Location TURBINE 1ST FLOOR

Environment Condition

Temperature 28.2 °C
Humidity 51 % RH

Calibration Result

Data Reading (Transmitter)						As Left					
As Found			As Left			As Found			As Left		
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	3.995	-0.005	-0.031	Pass						
411.8	8.001	7.988	-0.013	-0.081	Pass						
823.7	11.999	12.001	0.002	0.012	Pass						
1235.6	15.999	15.985	-0.014	-0.088	Pass						
1647.4	20.001	19.971	-0.030	-0.188	Pass						
1647.4	20.001	19.971	-0.030	-0.188	Pass						
1235.6	15.999	15.994	-0.005	-0.031	Pass						
823.7	12.000	11.986	-0.014	-0.087	Pass						
411.8	8.000	8.007	0.007	0.044	Pass						
0.0	4.000	3.996	-0.004	-0.025	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter.

This certificate comprise of 1 page
Date of issue, 08-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Faihsol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

