

CERTIFICATE OF CALIBRATION

TEMPERATURE SENSOR

Certificate No. : 0768-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAB02CT005
Instrument Description TURBINE DRIVEN BOILER FEEDWATER PUMP B INLET WATER
TEMPERATURE
Manufacture YAMARI
Model / Serial Number - / 5346932
Instrument Location TURBINE 1ST FLOOR

Range 0 ~ 250
Unit °C
Out. Signal 4 - 20 mA
Max. Deviation 2.5 °C
Cal. Date 30-05-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 27.1 °C Humidity 63 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	39.600	39.600	0.000	Pass					
62.5	62.100	62.500	0.400	Pass					
125.0	126.000	125.900	-0.100	Pass					
187.5	189.500	189.300	-0.200	Pass					
250.0	251.600	252.200	0.600	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	3611011	MAL 26031229	06-03-2026
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 31-05-2026

Customer Signature,

Ayrtan Humardani Putradhi

Ap. HERVITAMA,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

