

## CERTIFICATE OF CALIBRATION

### DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0317-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No.	60LAB03CF005	Range	0 ~ 1619.8
Instrument Description	MOTOR DRIVEN BOILER FEEDWATER PUMP INLET WATER FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	90Y616298	Cal. Date	08-05-2024
Instrument Location	TURBINE 1ST FLOOR		

#### Environment Condition

Temperature 27.8 °C  
Humidity 50 % RH

#### Calibration Result

Data Reading (Transmitter)											
As Found			As Left								
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.000	0.000	0.000	Pass						
405.0	7.999	7.994	-0.005	-0.031	Pass						
809.9	12.000	11.994	-0.006	-0.038	Pass						
1214.9	16.000	15.992	-0.008	-0.050	Pass						
1619.8	20.000	19.986	-0.014	-0.087	Pass						
1619.8	20.000	19.986	-0.014	-0.087	Pass						
1214.9	16.000	16.008	0.008	0.050	Pass						
809.9	12.000	12.000	0.000	0.000	Pass						
405.0	8.000	7.994	-0.006	-0.038	Pass						
0.0	4.000	4.002	0.002	0.012	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 700P05	14270508	S. 22 011 744	20-09-2022

#### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 09-05-2024

Customer Signature,



Ayrton Humardani Putradhi


HERVITAMA Laboratory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

