

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0321-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAB06CP005	Range	0 ~ 500
Instrument Description	TURBINE DRIVEN BOILER FEEDWATER PUMP B OUTLET WATER PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX530A	Max. Error	0.5 %
Serial Number	91V703044	Cal. Date	07-05-2024
Instrument Location	TURBINE 1ST FLOOR		

### Environment Condition

Temperature 32.5 °C  
Humidity 62 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	3.984	-0.016	-0.100	Pass						
125.00	8.000	7.988	-0.012	-0.075	Pass						
250.00	12.000	11.987	-0.013	-0.081	Pass						
375.01	16.000	15.988	-0.012	-0.075	Pass						
500.01	20.000	19.985	-0.015	-0.094	Pass						
500.01	20.000	19.985	-0.015	-0.094	Pass						
375.01	16.000	15.987	-0.013	-0.081	Pass						
250.00	12.000	11.986	-0.014	-0.087	Pass						
125.00	8.000	7.983	-0.017	-0.106	Pass						
0.00	4.000	3.983	-0.017	-0.106	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 08-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,




M. Taufiq Nur Fitriyan

INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

Calibrated by,



Handi Suryawinata

