

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0394-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAB08CP001 Range 0 ~ 400
Instrument Description BOILER FEEDWATER PUMP OUTLET WATER PRESSURE 1 Unit bar
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX 440A / 91V703033 Max. Error 0.5 %
Instrument Location TURBINE 2ND FLOOR Cal. Date 24-05-2026

Environment Condition

Temperature 32 °C Humidity 65 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
0.000	4.000	4.005	0.005	0.031	Pass						
100.040	8.001	8.000	-0.001	-0.006	Pass						
200.020	12.000	11.993	-0.007	-0.044	Pass						
300.060	16.002	15.989	-0.013	-0.081	Pass						
400.030	20.001	19.980	-0.021	-0.131	Pass						
300.060	16.002	15.993	-0.009	-0.056	Pass						
200.020	12.000	11.995	-0.005	-0.031	Pass						
100.040	8.001	8.000	-0.001	-0.006	Pass						
0.000	4.000	4.005	0.005	0.031	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method


0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 26-05-2026

Customer Signature,


Ayrtan Humardani Putradhi

Approved Signatory,


Ivan Hasan As
HERVITAMA
INDONESIA

Calibrated by,


Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person