

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0589-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAB08CT005	Range	0 ~ 250
Instrument Description	BOILER FEEDWATER PUMP OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	2.5 °C
Serial Number	5346937	Cal. Date	16-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 30.7 °C  
 Humidity 49 % RH

### Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.000	40.100	0.100	Pass					
62.5	62.500	62.900	0.400	Pass					
125.0	124.990	126.300	1.310	Pass					
187.5	187.500	189.200	1.700	Pass					
250.0	250.010	251.900	1.890	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Authorized Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khâbib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

