

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0591-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LAB08CT015 Range 0 ~ 300
 Instrument Description HP HEATER 7A OUTLET WATER Unit °C
 Manufacture YAMARI Out. Signal 4 - 20 mA
 Model - Max. Deviation 3 °C
 Serial Number 5346939 Cal. Date 16-05-2024
 Instrument Location TURBINE 3RD FLOOR Temp. Element Thermocouple Type E

Environment Condition

Temperature 26.3 °C
 Humidity 53 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.200	0.200	Pass					
120	120.010	121.900	1.890	Pass					
180	180.010	182.700	2.690	Pass					
240	240.020	242.800	2.780	Pass					
300	300.000	302.800	2.800	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 17-05-2024

Calibrated by,

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



INDONESIA Fitriyan



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

