

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0594-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAB09CT010	Range	0 ~ 250
Instrument Description	HP HEATER 6B OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	2.5 °C
Serial Number	5346941	Cal. Date	21-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.8 °C
Humidity 49 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.020	40.300	0.280	Pass					
62.5	62.510	63.200	0.690	Pass					
125.0	125.000	126.700	1.700	Pass					
187.5	187.50	189.600	2.100	Pass					
250.0	250.000	252.200	2.200	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 22-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taqim Nur Fitriyan

Calibrated by,



Khajib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

