

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0595-24-HI-CAL-10D

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60LAB09CT015
 Instrument Description: HP HEATER 7B OUTLET WATER TEMPERATURE
 Manufacture: YAMARI
 Model: -
 Serial Number: 5346942
 Instrument Location: TURBINE 3RD FLOOR

Range: 0 ~ 300
 Unit: °C
 Out. Signal: 4 - 20 mA
 Max. Deviation: 3 °C
 Cal. Date: 20-05-2024
 Temp. Element: Thermocouple Type E

Environment Condition

Temperature: 27.8 °C
 Humidity: 52 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass					
120	120.000	121.100	1.100	Pass					
180	180.010	180.700	0.690	Pass					
240	239.990	242.600	2.610	Pass					
300	300.000	302.900	2.900	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approver Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

