

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0596-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LAB09CT020 Range 0 ~ 350
 Instrument Description HP HEATER 8B OUTLET WATER Unit °C
 TEMPERATURE
 Manufacture YAMARI Out. Signal 4 - 20 mA
 Model - Max. Deviation 3.5 °C
 Serial Number 5346983 Cal. Date 16-05-2024
 Instrument Location TURBINE 3RD FLOOR Temp. Element Thermocouple Type E

Environment Condition

Temperature 29 °C
 Humidity 62 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.000	40.200	0.200	Pass										
87.5	87.520	88.500	0.980	Pass										
175.0	175.000	177.100	2.100	Pass										
262.5	262.540	264.300	1.760	Pass										
350.0	349.990	352.600	2.610	Pass										

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 17-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. INDONESIAIyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person