

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0325-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.: 60LAB11CF001  
 Instrument Description: ECONOMIZER INLET FEEDWATER FLOW 1  
 Manufacture: YOKOGAWA  
 Model: EJX110A  
 Serial Number: 91V500791  
 Instrument Location: BOILER 6TH FLOOR

Range: 0 ~ 1100  
 Unit: mbar  
 Out. Signal: 4 - 20 mA  
 Max. Error: 0.5 %  
 Cal. Date: 16-05-2024

### Environment Condition

Temperature: 27.3 °C  
 Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.000	0.000	0.000	Pass						
275	8.000	8.000	0.000	0.000	Pass						
550	12.001	12.006	0.005	0.031	Pass						
825	15.996	16.003	0.007	0.044	Pass						
1100	19.999	20.004	0.005	0.031	Pass						
1100	19.999	20.004	0.005	0.031	Pass						
825	16.000	16.005	0.005	0.031	Pass						
550	11.999	12.006	0.007	0.044	Pass						
275	8.000	8.000	0.000	0.000	Pass						
0	4.001	4.001	0.000	0.000	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,




M. Taufiq Nur Elriyan  
 INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

