

CERTIFICATE OF CALIBRATION

DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0327-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAB11CF003	Range	0 ~ 1100
Instrument Description	ECONOMIZER INLET FEEDWATER FLOW 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V500793	Cal. Date	16-05-2024
Instrument Location	BOILER 6TH FLOOR		

Environment Condition

Temperature: 27.3 °C
 Humidity: 51 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.001	0.001	0.006	Pass						
275	8.000	8.000	0.000	0.000	Pass						
550	12.000	12.005	0.005	0.031	Pass						
825	16.000	16.003	0.003	0.019	Pass						
1100	20.000	20.001	0.001	0.006	Pass						
1100	20.000	20.001	0.001	0.006	Pass						
825	16.000	16.004	0.004	0.025	Pass						
550	12.000	12.000	0.000	0.000	Pass						
275	8.000	8.005	0.005	0.031	Pass						
0	4.000	4.000	0.000	0.000	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory



M. Fauzan
 INDONESIA

Calibrated by,



Faihsol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person