

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0599-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LAB11CT002 Range 0 ~ 400
 Instrument Description ECONOMIZER INLET FEEDWATER Unit °C
 TEMPERATURE 2
 Manufacture YAMARI Out. Signal 4 - 20 mA
 Model - Max. Deviation 4 °C
 Serial Number 5451707 Cal. Date 10-05-2024
 Instrument Location BOILER 7TH FLOOR Temp. Element Thermocouple Type E

Environment Condition

Temperature 49.6 °C
 Humidity 54 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass					
100	100.000	100.000	0.000	Pass					
200	200.000	201.200	1.200	Pass					
300	300.000	301.100	1.100	Pass					
400	400.000	402.300	2.300	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
Dry Block Calibrator Ametek	506481-00011	S.24 - 00201	27-02-2024

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 11-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

