

REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0882-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60LAC11AA802 Power Supply 380 VAC
 Instrument Description BFPT A CASING DRAIN VALVE Stroke 20 mm
 Manufacture ROTORK
 Model 1010F10A Inspection Date 10-05-2024
 Serial Number 2606400901
 Instrument Location TURBINE 1ST FLOOR

Environment Condition

Temperature 32 °C
 Humidity 38 % RH

Traveling Time

Open to Close 13.84 s
 Close to Open 12.99 s

Stroke Result

| Command | Local | Stroke | DCS FB |
|---------|-------|--------|--------|
| [%] | [%] | [mm] | [%] |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
 Corrosion Condition OK Not OK Accessories Check OK Not OK
 Gearbox Condition OK Not OK

Remark

Open - Close : 20 mm

Test Equipment

| Description | Serial Number | Certificate Number | Calibration Date |
|------------------------------|---------------|--------------------|------------------|
| Digital Multimeter Fluke 87V | 16230349 | S. 22 008 274 | 08-07-2022 |
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person