

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0329-24-HI-CAL-10C

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAC11CP005	Range	-1 ~ 15
Instrument Description	BFPT A 1ST STAGE PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V829732	Cal. Date	12-05-2024
Instrument Location	TURBINE 1ST FLOOR		

### Environment Condition

Temperature 32.4 °C  
 Humidity 61 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.800	4.200	4.205	0.005	0.031	Pass						
3.000	8.000	7.998	-0.002	-0.012	Pass						
7.000	12.000	11.987	-0.013	-0.081	Pass						
11.000	16.000	15.989	-0.011	-0.069	Pass						
15.000	20.000	19.980	-0.020	-0.125	Pass						
11.000	20.000	19.980	-0.020	-0.125	Pass						
11.000	16.000	15.988	-0.012	-0.075	Pass						
7.000	12.000	11.988	-0.012	-0.075	Pass						
3.000	8.000	7.987	-0.013	-0.081	Pass						
-0.800	4.200	4.189	-0.011	-0.069	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 13-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Authorized Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

