

## REPORT OF INSPECTION MOTORIZED OF VALVE Certificate No. : 1220-24-HI-CAL-10J

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.

### Instrument Information

KKS No. 60LAC12AA801 Power Supply 380 VAC  
 Instrument Description BFPT B CASING DRAIN 2ND ISOLATION VALVE Stroke 20 mm  
 Manufacture ROTORK Inspection Date 10-05-2024  
 Model 1Q12F10A  
 Serial Number NT38303601  
 Instrument Location TURBINE 1st FLOOR

### Environment Condition

Temperature 31.1 °C Traveling Time  
 Open to Close 16.11 s  
 Humidity 36 % RH Close to Open 12.94 s

### Stroke Result

| Command | Local | Stroke | DCS FB |
|---------|-------|--------|--------|
| [%]     | [%]   | [mm]   | [%]    |
|         |       |        |        |
|         |       |        |        |
|         |       |        |        |
|         |       |        |        |
|         |       |        |        |

| Command | Feedback |       |      |       |
|---------|----------|-------|------|-------|
|         | Local    |       | DCS  |       |
|         | Open     | Close | Open | Close |
| Close   | -        | OK    | -    | OK    |
| Open    | OK       | -     | OK   | -     |

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Gearbox Condition  OK  Not OK

### Remark

### Test Equipment

| Description     | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03       | S. 23 004 599      | 27-03-2023       |

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 11-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

