

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0330-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60LAC12CP005 Range -1 ~ 15  
 Instrument Description BFPT B 1ST STAGE PRESSURE Unit barg  
 Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
 Model EJX430A Max. Error 0.5 %  
 Serial Number 91V829733 Cal. Date 12-05-2024  
 Instrument Location TURBINE 1ST FLOOR

### Environment Condition

Temperature 32.4 °C  
 Humidity 61 % RH

### Calibration Result

| Data Reading (Transmitter) |            |            |           |        |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |        |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [barg]                     | [mA]       | [mA]       |           | [%]    |        | [barg]  | [mA]       | [mA]       |           | [%]   |        |
| -0.800                     | 4.200      | 4.180      | -0.020    | -0.125 | Pass   |         |            |            |           |       |        |
| 3.000                      | 8.000      | 7.974      | -0.026    | -0.162 | Pass   |         |            |            |           |       |        |
| 7.000                      | 12.000     | 11.975     | -0.025    | -0.156 | Pass   |         |            |            |           |       |        |
| 11.000                     | 16.000     | 15.976     | -0.024    | -0.150 | Pass   |         |            |            |           |       |        |
| 15.000                     | 20.000     | 19.957     | -0.043    | -0.269 | Pass   |         |            |            |           |       |        |
| 11.000                     | 20.000     | 19.957     | -0.043    | -0.269 | Pass   |         |            |            |           |       |        |
| 11.000                     | 16.000     | 15.982     | -0.018    | -0.113 | Pass   |         |            |            |           |       |        |
| 7.000                      | 12.000     | 11.974     | -0.026    | -0.162 | Pass   |         |            |            |           |       |        |
| 3.000                      | 8.000      | 7.973      | -0.027    | -0.169 | Pass   |         |            |            |           |       |        |
| -0.800                     | 4.200      | 4.178      | -0.022    | -0.138 | Pass   |         |            |            |           |       |        |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011       | S. 22 011 747      | 23-09-2023       |
| Fluke Pressure Module 750PD27            | 6087359       | S. 23 014 459      | 09-10-2023       |

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 13-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

