

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0806-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAC12CT025
Instrument Description BFPT B 1ST STAGE METAL TEMPERATURE
Manufacture YAMARI
Model / Serial Number - / -
Instrument Location TURBINE 1ST FLOOR

Range 0 ~ 400
Unit °C
Out. Signal 4-20 mA
Max. Deviation 4 °C
Cal. Date 23-06-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 29.1 °C Humidity 53 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-0.700	-0.700	Pass					
100	100.000	99.500	-0.500	Pass					
200	200.000	199.500	-0.500	Pass					
300	300.000	299.600	-0.400	Pass					
400	400.000	399.600	-0.400	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description Serial Number Certificate Number Calibration Date
Temperature Calibrator Fluke 725 2815000 2256/25/KAL/06/2025 23-06-2025

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 24-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Khabib Mundzirul Umam

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

