

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0333-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAD11CL015	Range	NWL-250 ~ NWL+660
Instrument Description	HP HEATER 6A LEVEL 3	Unit	mm
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	-	Max. Error	0.5 %
Serial Number	91V701648	Cal. Date	20-05-2024
Instrument Location	TURBINE 3RD FLOOR		

Environment Condition

Temperature 33 °C
 Humidity 43 % RH

Calibration Result

Data Reading (Transmitter)																
As Found								As Left								
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-250	-250	-251.8	4.000	3.980	-0.020	-0.125	Pass									
-22.5	-22.5	-23.0	8.000	8.010	0.010	0.063	Pass									
205	205	205.1	12.000	12.010	0.010	0.063	Pass									
432.5	432.5	431.7	16.000	16.000	0.000	0.000	Pass									
660	660	660.4	20.000	20.010	0.010	0.063	Pass									

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,
HERVITAMA



M. Indonesia Ryan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

