

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0408-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60LAD21CL005

Instrument Description

HP HEATER 7A LEVEL 1

Manufacture

YOKOGAWA

Model / Serial Number

- / 91V7003469307

Instrument Location

TURBINE 3RD FLOOR

Range

-250 ~ 660

Unit

mm

Out. Signal

4 - 20 mA

Max. Error

0.5%

Cal. Date

28-05-2026

Environment Condition

Temperature

30 °C

Humidity

84 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-250	-222	-231	4.487	-9.000	-0.989	Fail	-250	-209	-210	4.712	-1.000	-0.110	Pass
-22.5	-7	-23	8.255	-16.000	-1.758	Fail	-22.5	-11	-9	8.230	2.000	0.220	Pass
205	191	179	11.751	-12.000	-1.319	Fail	205	186	187	11.685	1.000	0.110	Pass
432.5	424	412	15.838	-12.000	-1.319	Fail	432.5	442	441	16.156	-1.000	-0.110	Pass
660	656	643	19.850	-13.000	-1.429	Fail	660	660	660	20.006	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description
DIGITAL LASER DISTANCE METER
STEEL TAPE MEASURESerial Number
18H114632
001/L1/HI/2026Certificate Number
02169/GQI-Sert/03/26
01231/GQI-Sert/02/26Calibration Date
09-03-2026
09-02-2026

Calibration Method

0005/SOP_BJS/2025

Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 25-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

