

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0410-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAD21CL015
Instrument Description HP HEATER 7A LEVEL 3
Manufacture YOKOGAWA
Model / Serial Number - / 91V7003479307
Instrument Location TURBINE 3RD FLOOR

Range -250 ~ 660
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 28-05-2026

Environment Condition

Temperature 30 °C Humidity 84 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-250	-200	-214	4.634	-14.000	-1.538	Fail	-250	-217	-214	4.628	3.000	0.330	Pass
-22.5	17	7	8.524	-10.000	-1.099	Fail	-225	-21	-19	8.062	2.000	0.220	Pass
205	217	207	12.034	-10.000	-1.099	Fail	205	103	104	11.624	1.000	0.110	Pass
432.5	439	430	15.963	-9.000	-0.989	Fail	432.5	334	334	14.272	0.000	0.000	Pass
660	658	656	19.933	-2.000	-0.220	Pass	660	658	658	19.476	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 25-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

