

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0340-24-HI-CAL-10C

Customer Information

Company Name: PT. Bumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60LAD22CL005
 Instrument Description: HP HEATER 7B LEVEL 1
 Manufacture: YOKOGAWA
 Model: -
 Serial Number: -
 Instrument Location: TURBINE 3RD FLOOR

Range: NWL-250 ~ NWL+660 mm
 Unit: mm
 Out. Signal: 4 - 20 mA
 Max. Error: 0.5 %
 Cal. Date: 19-05-2024

Environment Condition

Temperature: 33 °C
 Humidity: 43 % RH

Calibration Result

Data Reading (Transmitter)																
As Found									As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]					[%]	[mm]	[mm]	[mm]				[mA]
-250	-250	-247.3	4.000	4.060	0.060	0.375	Pass									
-22.5	-22.5	-22.4	8.000	8.000	0.000	0.000	Pass									
205	205	204.9	12.000	12.000	0.000	0.000	Pass									
432.5	432.5	432.2	16.000	15.990	-0.010	-0.063	Pass									
660	660	658.7	20.000	19.970	-0.030	-0.188	Pass									

Standard Reference

Description: Digital Multimeter Fluke 87V
 Serial Number: 49910296
 Certificate Number: S. 22 008 273
 Calibration Date: 13-07-2022

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 20-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan

Calibrated by,

R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person