

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0343-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAD31CL005	Range	NWL-250 ~ NWL+660
Instrument Description	HP HEATER 8A LEVEL 1	Unit	mm
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	-	Max. Error	0.5 %
Serial Number	91V700351	Cal. Date	20-05-2024
Instrument Location	TURBINE 4TH FLOOR		

### Environment Condition

Temperature: 33 °C  
 Humidity: 43 % RH

### Calibration Result

Data Reading (Transmitter)																
As Found								As Left								
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-250	-250	-250.4	4.000	4.000	0.000	0.000	Pass									
-22.5	-22.5	-23.1	8.000	7.990	-0.010	-0.063	Pass									
205	205	204.9	12.000	12.000	0.000	0.000	Pass									
432.5	432.5	432.1	16.000	15.990	-0.010	-0.063	Pass									
660	660	660.0	20.000	20.000	0.000	0.000	Pass									

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
 Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signature,



M. Tauriq Nur Fitriyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

