

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0415-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-26-0004-OTH

### Instrument Information

KKS No. 60LAD31CL010  
 Instrument Description HP HEATER 8A LEVEL 2  
 Manufacture YOKOGAWA  
 Model / Serial Number EJX118A / 91V7003529377  
 Instrument Location TURBINE 4TH FLOOR

Range -250 ~ 660  
 Unit mm  
 Out. Signal 4 - 20 mA  
 Max. Error 0.5%  
 Cal. Date 07-06-2026

### Environment Condition

Temperature 26 °C Humidity 64 % RH

### Calibration Result

| Data Reading (Transmitter) |            |            |            |           |        |        |         |            |            |            |           |       |        |
|----------------------------|------------|------------|------------|-----------|--------|--------|---------|------------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |            |           |        |        | As Left |            |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Output UUT | Deviation | Error | Result |
| [mm]                       | [mm]       | [mm]       | [mA]       |           | [%]    |        | [mm]    | [mm]       | [mm]       | [mA]       |           | [%]   |        |
| -250                       | -219       | -222       | 4.442      | -3.000    | -0.330 | Pass   |         |            |            |            |           |       |        |
| -22.5                      | -18        | -20        | 8.033      | -2.000    | -0.220 | Pass   |         |            |            |            |           |       |        |
| 205                        | 174        | 175        | 11.484     | 1.000     | 0.110  | Pass   |         |            |            |            |           |       |        |
| 432.5                      | 412        | 413        | 15.654     | 1.000     | 0.110  | Pass   |         |            |            |            |           |       |        |
| 660                        | 658        | 658        | 19.964     | 0.000     | 0.000  | Pass   |         |            |            |            |           |       |        |

### Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
 Accessories Check ☒ Power Supply ☒

### Standard Reference

| Description                  | Serial Number  | Certificate Number   | Calibration Date |
|------------------------------|----------------|----------------------|------------------|
| DIGITAL LASER DISTANCE METER | 18H114632      | 02169/GQI-Sert/03/26 | 09-03-2026       |
| STEEL TAPE MEASURE           | 001/L1/HI/2026 | 01231/GQI-Sert/02/26 | 09-02-2026       |

### Calibration Method

0005/SOP\_BJS/2025  
 Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages  
 Date of issue, 12-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Authorized by,

INDONESIA  
 Ivan Hasan Ashari

Calibrated by,

RAISHOL ANWAR

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person