

## CERTIFICATE OF CALIBRATION

### LEVEL TRANSMITTER

Certificate No. : 0345-24-HI-CAL-10C

#### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

#### Instrument Information

KKS No.: 60LAD31CL015 Range: NWL-250 ~ NWL+660  
Instrument Description: HP HEATER 8A LEVEL 3 Unit: mm  
Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA  
Model: - Max. Error: 0.5 %  
Serial Number: 91V700353 Cal. Date: 20-05-2024  
Instrument Location: TURBINE 4TH FLOOR

#### Environment Condition

Temperature: 33 °C  
Humidity: 42 % RH

#### Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-250.0	-250.0	-252.0	4.000	3.980	-0.020	-0.125	Pass								
-22.5	-22.5	-22.3	8.000	8.010	0.010	0.063	Pass								
205.0	205.0	204.0	12.000	12.010	0.010	0.063	Pass								
432.5	432.5	432.5	16.000	16.000	0.000	0.000	Pass								
660.0	660.0	659.8	20.000	20.000	0.000	0.000	Pass								

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

#### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Prityan

Calibrated by,



R. Hery Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

