

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0346-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.: 60LAD32CL005 Range: NWL-250 ~ NWL+660  
 Instrument Description: HP HEATER 8B LEVEL 1 Unit: mm  
 Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA  
 Model: - Max. Error: 0.5 %  
 Serial Number: 91V700354 Cal. Date: 20-05-2024  
 Instrument Location: TURBINE 4TH FLOOR

### Environment Condition

Temperature: 33 °C  
 Humidity: 43 % RH

### Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-250	-250	-251.2	4.000	3.990	-0.010	-0.063	Pass								
-22.5	-22.5	-21.8	8.000	8.020	0.020	0.125	Pass								
205	205	205.4	12.000	12.010	0.010	0.063	Pass								
432.5	432.5	431.4	16.000	15.970	-0.030	-0.188	Pass								
660	660	659.1	20.000	19.980	-0.020	-0.125	Pass								

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
 Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Hidayat

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

