

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0417-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAD32CL005 Range -250 ~ 660
Instrument Description HP HEATER 8B LEVEL 1 Unit mm
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX118A / 91V7003549377 Max. Error 0.5%
Instrument Location TURBINE 4TH FLOOR Cal. Date 06-06-2026

Environment Condition

Temperature 26 °C Humidity 64 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-250	-229	-189	-	40.000	4.396	Fail	-250	-234	-236	4.247	-2.000	-0.220	Pass
-22.5	-19	-25	-	-6.000	-0.659	Fail	-22.5	-7	-6	8.296	1.000	0.110	Pass
205	185	227	-	42.000	4.615	Fail	205	214	213	12.151	-1.000	-0.110	Pass
432.5	459	500	-	41.000	4.505	Fail	432.5	456	453	16.374	-3.000	-0.330	Pass
660	659	698	-	39.000	4.286	Fail	660	660	660	20.006	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person