

CERTIFICATE OF CALIBRATION

LEVEL TRANSMITTER

Certificate No. : 0348-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60LAD32CL015 Range: NWL-250 ~ NWL+660
 Instrument Description: HP HEATER 8B LEVEL 3 Unit: mm
 Manufacture: YOKOGAWA Out. Signal: 4 - 20 mA
 Model: Max. Error: 0.5 %
 Serial Number: 91V700356 Cal. Date: 20-05-2024
 Instrument Location: TURBINE 4TH FLOOR

Environment Condition

Temperature: 33 °C
 Humidity: 43 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-250.0	-250.0	-249.7	4.000	4.010	0.010	0.063	Pass								
-22.5	-22.5	-21.7	8.000	8.020	0.020	0.125	Pass								
205.0	205.0	205.7	12.000	12.010	0.010	0.063	Pass								
432.5	432.5	432.0	16.000	16.000	0.000	0.000	Pass								
660.0	660.0	661.2	20.000	20.020	0.020	0.125	Pass								

Standard Reference

Description: Digital Multimeter Fluke 87V
 Serial Number: 49910296
 Certificate Number: S. 22 008 273
 Calibration Date: 13-07-2022

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 21-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Taufiq Nur Fauzan

Calibrated by,

R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

