

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0419-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAD32CL015
Instrument Description HP HEATER 8B LEVEL 3
Manufacture YOKOGAWA
Model / Serial Number EJX118A / 91V7003569377
Instrument Location TURBINE 4TH FLOOR

Range -250 ~ 660
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 06-06-2026

Environment Condition

Temperature 26 °C Humidity 64 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-250	-229	-272	-	-43.000	-4.725	Fail	-250	-202	-200	4.857	2.000	0.220	Pass
-22.5	-25	-72	-	-47.000	-5.165	Fail	-22.5	-6	-3	8.310	3.000	0.330	Pass
205	219	175	-	-44.000	-4.835	Fail	205	246	247	12.712	1.000	0.110	Pass
432.5	454	407	-	-47.000	-5.165	Fail	432.5	437	437	16.059	0.000	0.000	Pass
660	656	657	-	1.000	0.110	Pass	660	659	658	19.815	-1.000	-0.110	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

Jyoti Hasan Aulahi

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person