

## CERTIFICATE OF CALIBRATION

### LEVEL TRANSMITTER

Certificate No. : 0349-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No.	60LAD41CL005	Range	CL-700 ~ CL ± 0
Instrument Description	NO.6 EXTRACTION STEAM DESUPERHEATER A LEVEL	Unit	mm
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model		Max. Error	0.5 %
Serial Number	91V301542	Cal. Date	01-06-2024
Instrument Location	TURBINE 2ND FLOOR		

#### Environment Condition

Temperature 33 °C  
Humidity 42 % RH

#### Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]	[mm]	[mm]	[mm]	[mA]	[mA]		[%]
-700	-700	-699.5	4.000	4.010	0.010	0.063	Pass						
-525	-525	-525.8	8.000	7.990	-0.010	-0.063	Pass						
-350	-350	-349.9	12.000	12.000	0.000	0.000	Pass						
-175	-175	-174.8	16.000	16.010	0.010	0.063	Pass						
0	0	0.4	20.000	19.990	-0.010	-0.063	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

#### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 02-06-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Itavia Nur-Hidayat

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

