

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0350-24-HI-CAL-10C

### Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAD41CL010	Range	CL-700 ~ CL ± 0
Instrument Description	NO.6 EXTRACTION STEAM DESUPERHEATER A LEVEL	Unit	mm
Manufacture	2	Out. Signal	4 - 20 mA
Model	YOKOGAWA	Max. Error	0.5 %
Serial Number	91V301543	Cal. Date	01-06-2024
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature 33 °C  
Humidity 42 % RH

### Calibration Result

Data Reading (Transmitter)						
As Found				As Left		
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]
-700	-700	-701.0	4.000	4.000	0.000	0.000 Pass
-525	-525	-525.0	8.000	8.010	0.010	0.063 Pass
-350	-350	-350.4	12.000	12.000	0.000	0.000 Pass
-175	-175	-175.3	16.000	16.000	0.000	0.000 Pass
0	0	0.3	20.000	20.000	0.000	0.000 Pass

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 02-06-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Fauzi Nugra Ariyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person