

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0351-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60LAD41CL015 Range CL-700 ~ CL ± 0  
 Instrument Description NO.6 EXTRACTION STEAM DESUPERHEATER A LEVEL Unit mm  
 Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
 Model - Max. Error 0.5 %  
 Serial Number 91V301547 Cal. Date 01-06-2024  
 Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 33 °C  
 Humidity 42 % RH

### Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-700	-700	-699.0	4.000	4.010	0.010	0.063	Pass								
-525	-525	-525.0	8.000	8.010	0.010	0.063	Pass								
-350	-350	-349.5	12.000	12.050	0.050	0.313	Pass								
-175	-175	174.9	16.000	16.010	0.010	0.063	Pass								
0	0	0.0	20.000	20.000	0.000	0.000	Pass								

### Standard Reference

Description Digital Multimeter Fluke 87V Serial Number 49910296 Certificate Number S. 22 008 273 Calibration Date 13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
 Date of issue, 02-06-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Teang Nur Sulhan

Calibrated by,

R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person