

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0422-26-HI-CAL-10

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAD41CL015
Instrument Description NO.6 EXTRACTION STEAM DESUPERHEATER A LEVEL 3
Manufacture YOKOGAWA
Model / Serial Number - / 91V301547
Instrument Location TURBINE 2ND FLOOR

Range -70.9 ~ -2.9
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-70.900	4.000	4.040	0.040	0.250	Pass						
-53.900	8.000	8.034	0.034	0.213	Pass						
-36.900	12.000	12.032	0.032	0.200	Pass						
-19.900	16.000	16.018	0.018	0.112	Pass						
-2.900	20.000	20.008	0.008	0.050	Pass						
-19.900	16.000	16.020	0.020	0.125	Pass						
-36.900	12.000	12.030	0.030	0.188	Pass						
-53.900	8.000	8.030	0.030	0.188	Pass						
-70.900	4.000	4.039	0.039	0.244	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	2448033	4482/25/EX/10/2025	26-09-2025
CALIBRATOR FLUKE 754			
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0005/SOP_BJS/2025

Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 18-06-2026

Customer Signature,

Arton Humardani Putradhi

Authorized Signatory,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

