

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0352-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAD42CL005	Range	CL-700 ~ CL ± 0
Instrument Description	NO.6 EXTRACTION STEAM DESUPERHEATER B LEVEL	Unit	mm
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	□	Max. Error	0.5 %
Serial Number	91V301545	Cal. Date	01-06-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 33 °C
Humidity 42 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-700	-700	-699.7	4.000	4.010	0.010	0.063	Pass								
-525	-525	-526.0	8.000	7.980	-0.020	-0.125	Pass								
-350	-350	-350.4	12.000	12.000	0.000	0.000	Pass								
-175	-175	-175.9	16.000	15.990	-0.010	-0.063	Pass								
0	0	0.6	20.000	19.990	-0.010	-0.063	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 02-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Pacific Nur-Hidayat

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

