

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 0424-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAD42CL010
Instrument Description NO.6 EXTRACTION STEAM DESUPERHEATER B LEVEL 2
Manufacture YOKOGAWA
Model / Serial Number - / 91V301544
Instrument Location TURBINE 2ND FLOOR

Range -69.9 ~ -1.9
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)										
As Found						As Left				
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]
-69.900	4.000	4.010	0.010	0.063	Pass					
-52.900	8.000	8.011	0.011	0.069	Pass					
-35.900	12.000	12.024	0.024	0.150	Pass					
-18.900	16.000	16.001	0.001	0.006	Pass					
-1.900	20.000	19.969	-0.031	-0.194	Pass					
-18.900	16.000	16.011	0.011	0.069	Pass					
-35.900	12.000	12.024	0.024	0.150	Pass					
-52.900	8.000	8.011	0.011	0.069	Pass					
-69.900	4.000	4.014	0.014	0.088	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0005/SOP_BJS/2025

Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages

Date of issue, 18-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

