

CERTIFICATE OF CALIBRATION

PRESSURE TRANSMITTER

Certificate No. : 0355-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAE01CP001	Range	0 ~ 400
Instrument Description	SUPERHEATER ATTEMPERATING SPRAY WATER PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V507033	Cal. Date	22-05-2024
Instrument Location	BOILER 7.5TH FLOOR		

Environment Condition

Temperature: 32 °C
Humidity: 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
100.04	8.002	8.002	0.000	0.000	Pass						
200.02	12.001	12.001	0.000	0.000	Pass						
300.06	16.002	16.006	0.004	0.025	Pass						
400.03	20.001	20.006	0.005	0.031	Pass						
400.03	20.001	20.006	0.005	0.031	Pass						
300.06	16.002	16.004	0.002	0.013	Pass						
200.02	12.001	12.002	0.001	0.006	Pass						
100.04	8.002	8.001	-0.001	-0.006	Pass						
0.00	4.000	4.000	0.000	0.000	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 23-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person

